

Govt. of Maharashtra Directorate of Maharashtra Fire Services PMC

Fire Dept.

To act as Licensed Agency for the Purposes of Fire Prevention & Life Safety Measures Act, 2006

DFEPL / SVIS / 12898 / 24-25

01-Jun-2024

SADHU VASWANI INTERNATIONAL SCHOOL Sadhu Vaswani Educational Complex, Sant Nagar, Moshi - Pradhikaran, Pune.

Site : SADHU VASWANI INTERNATIONAL SCHOOL Sant Nagar, Moshi - Pradhikaran, Pune.

1 Bldg. (B + Gr. Fl. + 4 Floors)

Dear Sir,

Encl. pl. find "B" Certificate.

NOTE :-

After Maintenance we have Handed Over the Systems with live Trials & Training to your personnel.

You / Occupiers are advised to carry out -

- i. Daily checks of Fire Protection Systems & Equipment.
- ii. Trials Every Month & Report to us for any malfunctioning.
- iii. Take all reqd. care with initiative to keep the Systems always in good working condition.
- iv. Do not neglect System Maintenance.
- v. Inform us about any Problem in System Operation immediately which we will attend at extra cost.

("B" Certificate is Mandatory in January & July every year get renewed.)

m.

FOR DISNYR FIRE ENTERPRISES PVT. LTD.

Encl. : a/a

CORPORATE OFFICE :

1094, Sadashiv Peth, Raghunath Chambers, Opp. Janata Sahakari Bank Ltd., Bajirao Road, Pune - 411030. Tel.: (020) 2447 7553 / 2443 0342. Email : disnyr.fire@gmail.com / disnyrfireiv@gmail.com Website : www.disnyrfire.com

REGD. OFFICE : 1070, Sadashiv Peth, Ramdoot Society, Pune - 411030.



Govt. of Maharashtra Directorate of Maharashtra Fire Services PMC Fire Dept.

To act as Licensed Agency for the Purposes of Fire Prevention & Life Safety Measures Act, 2006

FORM B [See section 3(3) and rule 4(2)]

Six Monthly Certificate for January 2024 for compliance of the Fire Prevention and Life Safety Measures.

CERTIFICATE

Certified that I / We have carried out inspection of the Fire Prevention &

Life Safety Measures installed in the following Building or Premises, namely :-

SADHU VASWANI INTERNATIONAL SCHOOL Sadhu Vaswani Educational Complex, Sant Nagar, Moshi - Pradhikaran, Pune. 1 Bldg. - (B + Gr. Fl. + 4 Floors)

I / We further certify that these installations in the above mentioned buildings

are maintained in good repair and efficient conditions during the Period

01-Jul-2023 to 31-Dec-2023 as required under the provisions of the -

Maharashtra Fire Prevention and Life Safety Measures Act, 2006

(Mah. III of 2007). The details of the Inspection & Maintenance of installations

carried out by me / us are mentioned in the report appended herewith.

Place : Pune

Date : 01.06.2024

Signature

Neelkanth V. Datar Disnyr Fire Ent. Pvt. Ltd. Licensed Agency Govt. of Maharashtra Directorate of Maharashtra Fire Services Licence No. : LA/0001/F-0021 Dt. : 12.05.2011

Copy to:

Owner /Occupier of the Bldg./Premises Chief Fire Officer of the Local Authority The Director of Maharashtra Fire Services Office Copy NEELKANT H VASUDEO DATAR DATAR Digitally signed by NEELKANTH VASUDEO VASUDEO DATAR Date: 2024.06.01 18:42:36 +05'30'

DISNYR FIRE ENTERPRISES PVT. LTD.

1094, Sadashiv Peth, Raghunath Chambers, Bajirao Road, Pune - 411 030. Tel. No. : 24477553/ 24430342 /24477545 Email : disnyr.fire@gmail.com disnyrfireiv@gmail.com

Encl. : Inspection / Compliance Report

CORPORATE OFFICE :

1094, Sadashiv Peth, Raghunath Chambers, Opp. Janata Sahakari Bank Ltd., Bajirao Road, Pune - 411030. Tel.: (020) 2447 7553 / 2443 0342. Email : disnyr.fire@gmail.com / disnyrfireiv@gmail.com Website : www.disnyrfire.com REGD. OFFICE : 1070, Sadashiv Peth, Ramdoot Society, Pune - 411030.



INSPECTION / COMPLIANCE REPORT FOR :- JANUARY 2024

Site :

SADHU VASWANI INTERNATIONAL SCHOOL "Sadhu Vaswani International School" Sant Nagar, Moshi - Pradhikaran, Pune. 1 Bldg. - (B + Gr. Fl. + 4 Floors)

Inspected on: 30.05.2024

Sr.	Equipment		Total Qty.	Remarks
[I] 1	WET RISER / DOWN CON Pipeline	IER SYST	 EM :- 05 Nos. 	
2	Valve at Terrace Lvl.		3 Nos.	
3	NRV at Terrace LvI.		3 Nos.	•
4	Booster Pump - 7.5 HP Cap. with Starter & cover		3 Nos.	As per our Survey Report
5	Single Outlet Hydt. Valve : ISI		26 Nos.	Missing Items Replacd
6	Bracket for Hoses		26 Nos.	Unserviceable Items -
7	Delivery Hose - 15 Mtrs. with Male / Female Couplings		52 Nos.	Serviced And
8	Short Branch		26 Nos.	Reqd. Repairs + Actions Taken.
9	Hose Reel with Shut off nozzle Rubber Hose	&	26 N <mark>o</mark> s.	Ensured Satisfactory
10	Fire Extinguishers			Working of the System.
	ABC Stored Pressure	6.0 Kg.	33 Nos.	4
	Carbon Di-Oxide (CO2)	3.0 Kg.	19 Nos.	





[11] 1	COURTYARD FIRE HYDRA			
2	Fire Service Inlet		3 Nos.	
3	Single Outlet Hydt. Valve : IS	5I	14 Nos.	As per our Survey Report Missing Items Replacd
4	Hose Box : Double		14 Nos.	
5	Delivery Hose - 15 Mtrs. with Male / Female Couplings		28 Nos.	
6	Short Branch		14 Nos.	Unserviceable Items - Serviced
[111]	AUTO SPRINKLER SYSTEI For Entire Bldg.	M :-		And Reqd. Repairs H
1	Pipeline			Actions Taken.
2	Sprinkler Bulbs		224 Nos. (Approx)	Ensured Satisfactory
3	Pumps	Capacity		Working
a b	Main Pump Standby Pump	60 HP 60 HP	1 No. 1 No.	of the System.
С	Jockey Pump	12.5 HP	1 No.	
4	Control Panel		1 No.	1

NOTE:

Training in System Operation -

Imparted to Security Personnel, Staff Members & Occupiers.

PUNE-30.

Occupiers advised to carry out -

Daily checks of Fire Protection Systems & Equipment.
Trials Every Month & Report to us for any malfunctioning.

NEELKANTH VASUDEO DATAR Digitally signed by NEELKANTH VASUDEO DATAR Date: 2024.06.01 18:43:14 +05'30'

FOR DISNYR FIRE ENTERPRISES PVT. LTD.

Page 2 of 2

i.

N